

WATERLOO IA

Latitude = 42.55 N

Longitude = 92.40 W

Period of Record = 1967 to 1996

WMO No. 725480

Elevation = 879 feet

Average Pressure = 29.05 inches Hg

Design Criteria Data

	Design Value	Mean Coincident (Average) Values			
		Wet Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Dry Bulb Temperature (T)	(°F)				
Median of Extreme Highs	96	76	108	13.4	S
0.4% Occurrence	92	75	107	12.9	S
1.0% Occurrence	89	73	103	12.8	S
2.0% Occurrence	86	72	98	12.2	S
Mean Daily Range	19	-	-	-	-
97.5% Occurrence	-2	-3	3	10.4	NW
99.0% Occurrence	-9	-9	2	9.9	NW
99.6% Occurrence	-15	-15	2	9.2	NW
Median of Extreme Lows	-19	-19	1	9.1	NW
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Humidity Ratio (gr/lb)	Wind Speed (mph)	Prevailing Direction (NSEW)
Wet Bulb Temperature (T_{wb})	(°F)				
Median of Extreme Highs	80	90	141	11.0	S
0.4% Occurrence	78	88	131	11.1	S
1.0% Occurrence	76	85	123	11.2	S
2.0% Occurrence	74	83	115	10.8	S
	Design Value	Mean Coincident (Average) Values			
		Dry Bulb Temperature (°F)	Vapor Pressure (in. Hg)	Wind Speed (mph)	Prevailing Direction (NSEW)
Humidity Ratio (HR)	(gr/lb)				
Median of Extreme Highs	148	87	0.94	13.6	S
0.4% Occurrence	135	85	0.88	9.6	S
1.0% Occurrence	127	82	0.82	9.3	S
2.0% Occurrence	118	80	0.77	9.8	S
Air Conditioning/ Humid Area Criteria	# of Hours	T ≥ 93°F	T ≥ 80°F	T _{wb} ≥ 73°F	T _{wb} ≥ 67°F
		27	590	300	1062


Other Site Data

Weather Region	Rain Rate 100 Year Recurrence (in./hr)	Basic Wind Speed 3 sec gust @ 33 ft 50 Year Recurrence (mph)	Ventilation Cooling Load Index (Ton-hr/cfm/yr) Base 75°F-RH 60% Latent + Sensible
5	3.3	90	1.3 + 0.5
Ground Water Temperature (°F) 50 Foot Depth *	Frost Depth 50 Year Recurrence (in.)	Ground Snow Load 50 Year Recurrence (lb/ft ²)	Average Annual Freeze-Thaw Cycles (#)
49.6	N/A	32	65


*Note: Temperatures at greater depths can be estimated by adding 1.5°F per 100 feet additional depth.

WATERLOO IA


WMO No. 725480



Long Term Psychrometric Summary



Psychrometric Summary of Peak Design Values



99% Dry Bulb	(°F)	MCHR (gr/lb)	Enthalpy (btu/lb)	1.0% Humidity Ratio	(gr/lb)	MCDB (°F)	MCWB (°F)	MC Dewpt (°F)	Enthalpy (btu/lb)
	-9	2.2	-1.8		126.7	82	75.5	73.1	39.5

1.0% Dry Bulb	(°F)	MCHR (gr/lb)	MCWB (°F)	Enthalpy (btu/lb)
	89	104.8	73.7	37.8

WATERLOO IA

WMO No. 725480

Dry-Bulb Temperature Hours For An Average Year (Sheet 1 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	January					February					March				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104															
95 / 99															
90 / 94															
85 / 89												0		0	63.0
80 / 84												1	0	1	61.4
75 / 79												1	0	1	60.8
70 / 74												2	1	3	56.5
65 / 69							0		0	53.0		0	4	2	6
60 / 64							1	0	1	48.7		1	7	5	13
55 / 59		1		1	44.5		1	0	1	45.9		4	13	7	24
50 / 54	0	1	0	1	44.8	0	3	1	4	44.3		5	18	12	35
45 / 49	0	2	1	3	40.3	1	8	3	12	40.2		9	26	20	55
40 / 44	1	8	4	13	36.8	3	16	10	29	37.2		15	37	30	82
35 / 39	9	18	15	42	33.8	14	30	28	72	33.8		45	46	45	135
30 / 34	28	33	37	98	30.2	37	37	44	118	30.0		57	40	53	149
25 / 29	28	34	34	96	25.2	33	28	31	92	25.0		43	25	32	99
20 / 24	31	35	33	99	20.4	29	25	24	78	20.3		29	13	18	60
15 / 19	27	24	23	74	15.9	21	21	21	63	15.6		16	8	9	33
10 / 14	25	27	24	76	10.8	19	19	19	57	10.7		9	5	8	22
5 / 9	22	21	23	66	5.9	18	13	16	47	6.0		7	3	4	14
0 / 4	21	16	19	56	1.1	16	10	13	39	1.2		4	1	2	7
-5 / -1	14	11	15	40	-3.3	10	5	7	22	-3.3		2	0	1	3
-10 / -6	17	10	12	39	-7.6	10	4	5	19	-7.5		2	0	0	2
-15 / -11	11	5	6	22	-12.1	6	2	3	11	-12.1		0			0
-20 / -16	7	3	4	14	-16.9	4	1	1	6	-16.6					
-25 / -21	3	1	1	5	-21.6	1	0	0	1	-21.6					
-30 / -26	1	0		1	-26.0	0	0	0	0	-27.0					
-35 / -31	0			0	-32.0	0		0	0						

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WATERLOO IA

WMO No. 725480

Dry-Bulb Temperature Hours For An Average Year (Sheet 2 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	April					May					June					
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	
	01	09	17			01	09	17			01	09	17			
	To 08	To 16	To 00			To 08	To 16	To 00			To 08	To 16	To 00			
100 / 104													0	0	0	75.1
95 / 99		0		0	65.3								2	1	3	74.9
90 / 94		0	0	0	64.4		1	0	1	68.7		10	3	13	72.9	
85 / 89		1	0	1	64.8		8	3	11	68.6		0	27	11	38	70.9
80 / 84		5	2	7	63.0	0	21	8	29	65.3	2	48	25	75	68.2	
75 / 79		7	4	11	61.0	1	31	17	49	63.0	12	53	40	106	66.1	
70 / 74	1	12	8	21	58.2	6	40	29	75	60.4	37	48	51	136	63.9	
65 / 69	4	23	11	38	55.1	23	42	38	103	58.4	54	30	47	131	61.3	
60 / 64	9	29	21	59	52.4	39	40	44	122	55.4	60	16	38	114	57.7	
55 / 59	12	32	30	74	48.9	42	33	42	116	51.4	40	4	17	60	53.6	
50 / 54	24	39	36	99	45.6	52	21	38	111	47.7	25	1	6	32	49.5	
45 / 49	37	33	39	110	42.4	43	9	19	71	43.7	8	0	1	9	45.4	
40 / 44	44	27	37	108	38.4	26	3	9	38	39.4	2	0	0	2	41.9	
35 / 39	47	19	29	95	34.1	11	0	2	13	34.5						
30 / 34	36	8	16	60	30.0	5	0	0	5	29.6						
25 / 29	16	2	7	25	25.3	0			0	26.5						
20 / 24	7	1	1	9	20.9											
15 / 19	2	0	0	2	15.5											
10 / 14	0	0	0	0	11.6											
5 / 9	0		0	0	6.6											
0 / 4	0			0	1.3											
-5 / -1	0			0	-2.0											
-10 / -6																
-15 / -11																
-20 / -16																
-25 / -21																
-30 / -26																
-35 / -31																

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WATERLOO IA

WMO No. 725480

Dry-Bulb Temperature Hours For An Average Year (Sheet 3 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	July					August					September				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104		0	0	0	75.1		1	0	1	75.9					
95 / 99		4	1	5	76.1		2	1	3	77.0		0		0	72.7
90 / 94		19	6	25	75.2		11	3	14	75.8		4	0	4	73.5
85 / 89	0	43	17	60	73.1	0	30	11	41	73.7		11	2	13	71.6
80 / 84	6	65	42	113	70.8	2	56	26	84	70.8	0	26	9	35	68.7
75 / 79	25	61	52	138	68.5	16	60	45	121	68.6	3	32	18	53	66.5
70 / 74	60	37	57	153	66.6	44	51	56	150	66.2	16	41	29	86	63.8
65 / 69	67	14	43	124	63.4	61	27	50	137	63.1	25	41	35	101	60.3
60 / 64	53	4	23	80	59.5	57	9	34	99	59.2	39	40	45	125	57.0
55 / 59	27	1	7	35	55.3	38	2	17	57	55.0	43	26	40	110	53.1
50 / 54	8		1	9	50.9	19	0	6	25	50.6	40	14	33	87	48.7
45 / 49	2		0	2	46.7	9		1	10	46.2	34	4	17	55	44.5
40 / 44	0			0	42.5	2		0	2	42.8	21	1	9	31	40.4
35 / 39											12	0	3	15	35.7
30 / 34											4		1	5	31.1
25 / 29											1		0	1	27.2
20 / 24															
15 / 19															
10 / 14															
5 / 9															
0 / 4															
-5 / -1															
-10 / -6															
-15 / -11															
-20 / -16															
-25 / -21															
-30 / -26															
-35 / -31															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WATERLOO IA

WMO No. 725480

Dry-Bulb Temperature Hours For An Average Year (Sheet 4 of 5)

Period of Record = 1967 to 1996

Temperature Range (°F)	October					November					December				
	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00			01 To 08	09 To 16	17 To 00		
100 / 104															
95 / 99															
90 / 94		0		0	62.0										
85 / 89		1	0	1	66.3										
80 / 84		3	1	4	64.9										
75 / 79		9	2	11	62.3		0		0	61.7					
70 / 74	0	16	6	22	59.7		1	0	1	58.5					
65 / 69	6	23	13	42	57.5	0	2	0	2	57.2		0		0	56.0
60 / 64	12	39	23	74	54.4	1	7	3	11	54.4		0	0	0	57.7
55 / 59	21	43	32	96	50.5	4	15	9	28	51.0	0	1	1	2	53.1
50 / 54	31	45	44	120	46.4	11	24	15	50	46.6	1	2	1	4	47.6
45 / 49	44	32	44	120	42.8	13	25	21	59	42.3	2	5	2	9	42.6
40 / 44	41	21	37	99	38.5	20	34	27	81	38.2	3	12	6	21	38.0
35 / 39	37	12	26	75	34.5	34	43	43	120	34.0	11	28	21	60	34.1
30 / 34	32	4	16	52	30.0	51	39	49	138	29.8	42	52	52	146	30.2
25 / 29	17	1	5	23	25.6	41	23	34	97	25.1	40	41	41	122	25.3
20 / 24	4		1	5	21.1	27	13	19	59	20.5	37	28	36	101	20.5
15 / 19	1		0	1	16.8	18	8	11	37	15.8	31	24	24	79	15.8
10 / 14	0			0	12.0	9	4	7	20	11.3	22	16	21	59	11.0
5 / 9						5	2	3	10	6.3	16	14	14	44	6.0
0 / 4						4	1	1	6	1.7	13	11	12	36	1.0
-5 / -1						1	0	0	1	-3.1	9	6	8	23	-3.1
-10 / -6						0	0	0	0	-7.5	9	4	6	19	-7.5
-15 / -11						0	0		0	-12.1	4	2	3	9	-12.2
-20 / -16						0			0	-17.0	4	1	2	7	-16.6
-25 / -21											2	0	0	2	-21.3
-30 / -26											0			0	-25.6
-35 / -31															

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

WATERLOO IA

WMO No. 725480


Dry-Bulb Temperature Hours For An Average Year (Sheet 5 of 5)

Period of Record = 1967 to 1996


Annual Totals					
Temperature Range (°F)	Hour Group (LST)			Total Obs	M C W B (°F)
	01 To 08	09 To 16	17 To 00		
100 / 104		2	0	2	75.5
95 / 99		9	3	12	76.0
90 / 94		46	13	59	74.5
85 / 89	1	122	45	167	72.2
80 / 84	11	226	112	350	69.4
75 / 79	59	255	177	491	66.9
70 / 74	164	249	238	651	64.3
65 / 69	242	205	240	687	60.8
60 / 64	272	192	235	699	56.6
55 / 59	232	171	201	603	51.9
50 / 54	218	168	191	577	47.2
45 / 49	202	144	166	511	42.9
40 / 44	178	159	166	502	38.4
35 / 39	219	194	210	624	34.1
30 / 34	293	212	266	771	30.0
25 / 29	219	154	182	555	25.2
20 / 24	165	115	132	411	20.4
15 / 19	116	86	88	290	15.8
10 / 14	85	70	78	233	10.8
5 / 9	69	52	58	179	5.9
0 / 4	58	38	46	141	1.1
-5 / -1	35	21	30	86	-3.3
-10 / -6	37	17	23	77	-7.6
-15 / -11	21	9	12	42	-12.1
-20 / -16	15	4	7	26	-16.7
-25 / -21	6	1	1	8	-21.5
-30 / -26	2	0	0	2	-26.2
-35 / -31	0		0	0	-32.0

Caution: This summary reflects the typical distribution of temperature in a typical year. It does not reflect the typical moisture distribution. Because wet bulb temperatures are averaged, this summary understates the annual moisture load. For accurate moisture load data, see the long-term humidity summary and the ventilation and infiltration load pages in this manual.

Annual Summary of Temperatures



Long Term Humidity and Dry Bulb Temperature Summary




WATERLOO IA

WMO No. 725480


Long Term Dry Bulb Temperature and Humidity Summary

Week Ending	1.0% Temp (°F)	MCWB @ 1% Temp (°F)	Mean Max Temp (°F)	Mean Min Temp (°F)	99% Temp (°F)	1.0% HR (gr/lb)	MCDB @ 1% HR (°F)	Mean Max HR (gr/lb)	Mean Min HR (gr/lb)
7-Jan	38.0	34.8	20.9	5.1	-16.0	28.7	34.5	14.3	7.5
14-Jan	42.0	36.5	22.8	5.7	-19.0	30.8	42.2	15.2	7.5
21-Jan	43.0	37.1	25.0	7.7	-22.0	35.0	38.1	17.0	8.8
28-Jan	43.0	37.2	27.0	10.2	-13.0	30.1	36.3	17.4	8.8
4-Feb	43.0	40.4	24.4	7.4	-20.0	36.4	42.0	16.3	8.4
11-Feb	47.0	39.8	25.2	7.5	-16.0	30.1	38.0	15.6	8.3
18-Feb	54.0	46.7	30.3	14.3	-10.0	37.8	46.7	18.9	11.0
25-Feb	51.0	45.0	34.5	18.5	-7.0	36.4	42.3	22.5	13.2
4-Mar	57.0	49.1	36.0	19.0	-2.0	51.1	52.4	22.6	12.7
11-Mar	62.0	52.9	38.4	20.8	-3.0	60.2	54.2	25.2	14.4
18-Mar	65.0	56.2	42.0	25.6	4.0	60.9	57.8	27.9	17.3
25-Mar	67.0	53.1	46.7	27.8	13.0	56.0	55.6	30.3	17.9
1-Apr	75.0	60.0	49.5	31.4	16.0	67.2	62.1	35.0	21.3
8-Apr	75.0	59.2	53.2	32.2	15.0	72.1	68.4	35.5	21.5
15-Apr	76.0	58.0	56.3	36.3	24.0	74.9	64.3	40.8	25.2
22-Apr	84.0	63.3	61.1	39.7	26.0	77.7	66.4	46.4	29.3
29-Apr	82.0	66.4	64.3	42.3	31.0	86.8	69.5	50.9	31.8
6-May	81.0	60.9	64.9	43.0	32.0	82.6	66.7	48.0	30.7
13-May	83.0	64.3	69.0	47.1	34.0	95.9	72.9	58.7	38.2
20-May	87.0	69.3	71.8	50.6	40.0	107.8	76.5	66.5	44.8
27-May	87.0	69.6	72.5	52.2	41.0	113.4	77.6	70.7	48.8
3-Jun	87.0	69.1	75.1	54.5	44.0	114.8	79.2	75.6	52.3
10-Jun	91.0	70.6	78.8	56.9	46.0	115.5	77.9	80.5	54.7
17-Jun	91.0	70.2	80.2	59.6	49.0	128.1	79.5	91.2	63.1
24-Jun	92.0	72.5	80.6	60.5	50.0	122.5	84.9	92.1	66.4
1-Jul	93.0	76.8	82.0	61.4	51.0	135.8	85.8	97.6	70.6
8-Jul	95.0	74.2	83.6	62.4	53.0	136.5	86.5	101.0	72.2
15-Jul	95.0	77.8	83.7	63.5	52.0	146.3	87.2	105.4	77.2
22-Jul	93.0	77.7	83.4	64.6	55.0	145.6	85.3	108.2	79.7
29-Jul	92.0	76.9	82.6	62.5	54.0	139.3	84.7	103.4	76.6
5-Aug	96.0	77.1	82.1	61.8	52.0	141.4	78.5	102.0	74.4
12-Aug	92.0	76.9	81.8	60.8	50.0	140.7	83.7	100.6	73.4
19-Aug	96.0	78.4	81.2	60.9	48.0	140.7	85.9	101.6	73.2
26-Aug	90.0	75.1	80.5	59.8	48.0	136.5	84.3	98.3	69.9
2-Sep	90.0	73.1	79.0	58.2	45.0	131.6	83.3	93.4	66.7
9-Sep	91.0	75.0	78.0	55.6	41.0	130.2	84.5	87.1	60.6
16-Sep	87.0	71.1	73.3	52.1	38.0	120.4	79.9	76.5	53.2
23-Sep	85.0	69.9	69.5	48.5	34.0	114.1	77.5	69.1	46.3
30-Sep	83.0	65.9	68.9	45.5	31.0	102.9	75.7	60.7	40.2
7-Oct	83.0	65.9	65.6	42.9	28.0	88.9	68.6	55.0	35.5
14-Oct	79.0	63.3	61.4	40.2	28.0	89.6	68.9	48.9	32.0
21-Oct	76.0	62.1	59.1	38.0	25.0	85.4	65.4	45.2	28.7
28-Oct	76.0	63.1	56.9	36.4	23.0	81.9	70.8	43.8	27.3
4-Nov	69.0	56.9	51.8	34.3	15.0	74.2	61.4	40.1	24.9
11-Nov	62.0	54.0	46.7	29.1	10.0	63.7	57.8	33.1	20.4
18-Nov	63.0	56.4	44.7	27.1	9.0	60.9	54.9	31.8	18.4
25-Nov	59.0	53.9	40.3	23.6	4.0	64.4	56.3	27.3	15.9
2-Dec	57.0	52.7	34.5	18.9	-3.0	56.0	55.2	24.2	13.3
9-Dec	49.0	44.6	31.8	15.9	-8.0	43.4	46.4	21.5	11.6
16-Dec	49.0	44.5	30.3	14.6	-12.0	41.3	46.5	20.8	11.5
23-Dec	45.0	41.7	27.2	12.1	-20.0	37.8	41.4	19.0	10.2
31-Dec	44.0	39.3	25.9	10.7	-15.0	38.5	42.6	17.9	9.7



	Mean Cooling Degree Days (°F)	Mean Heating Degree Days (°F)
JAN	0	1519
FEB	0	1233
MAR	2	958
APR	18	525
MAY	71	221
JUN	185	58
JUL	265	25
AUG	209	49
SEP	86	193
OCT	16	500
NOV	0	915
DEC	0	1346
ANN	852	7542

Average Ventilation and Infiltration Loads
(Outside Air vs. 75°F, 60% RH summer; 68°F, 30% RH winter)



	Average Sensible Cooling Load	Average Sensible Heating Load	Average Latent Cooling Load	Average Latent Heating Load
	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)	(Btu/cfm)
JAN	0	-41785	0	-8841
FEB	0	-34151	0	-7023
MAR	6	-27174	0	-4827
APR	92	-15752	16	-1946
MAY	400	-7383	547	-396
JUN	1408	-2397	2744	-4
JUL	2279	-1205	5981	0
AUG	1598	-2071	5252	0
SEP	533	-6538	1538	-140
OCT	57	-15160	51	-1488
NOV	0	-26011	0	-4342
DEC	0	-37315	0	-7512
ANN	6373	-216942	16129	-36519

Average Annual Solar Radiation – Nearest Available Site

(Source: National Renewable Energy Laboratory, Golden CO, 1995)

City: WATERLOO
 State: IA
 WBAN No: 94910
 Lat(N): 42.55
 Long(W): 92.4
 Elev(ft): 869

Stn Type: Secondary
 SHADING GEOMETRY IN DIMENSIONLESS UNITS
 Window: 1
 Overhang: 0.607
 Vert Gap: 0.329

AVERAGE INCIDENT SOLAR RADIATION (Btu/sq.ft./day), Percentage Uncertainty = 9		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
HORIZ	Global	600	860	1150	1490	1810	2010	1990	1740	1350	960	590	480	1250
	Std Dev	49	51	93	121	121	116	123	102	117	82	46	40	40
	Minimum	490	740	940	1290	1540	1810	1740	1480	1090	770	470	410	1180
	Maximum	680	960	1350	1760	2060	2330	2230	1930	1630	1130	670	580	1380
	Diffuse	310	440	590	710	810	850	800	710	570	420	320	270	570
Clear Day	Global	810	1170	1660	2170	2510	2640	2550	2240	1780	1260	850	690	1700
NORTH	Global	190	260	350	440	550	630	600	480	370	270	190	160	370
	Diffuse	190	260	350	430	500	540	520	450	370	270	190	160	350
Clear Day	Global	160	230	310	420	570	690	630	470	340	250	170	150	370
EAST	Global	420	570	720	890	1040	1120	1120	1000	820	630	390	340	760
	Diffuse	230	330	430	520	600	640	630	560	450	340	240	200	430
Clear Day	Global	640	860	1130	1350	1470	1510	1470	1360	1170	900	670	560	1090
SOUTH	Global	1030	1130	1070	980	900	860	900	1010	1110	1140	880	860	990
	Diffuse	350	440	500	540	580	600	590	560	510	420	330	300	480
Clear Day	Global	1880	2000	1870	1500	1170	1030	1080	1340	1670	1870	1850	1780	1580
WEST	Global	420	560	710	880	1030	1130	1150	1040	860	630	400	340	760
	Diffuse	240	330	430	520	610	660	640	570	460	340	240	200	440
Clear Day	Global	640	860	1130	1350	1470	1510	1470	1360	1170	900	670	560	1090

Average Annual Solar Heat and Illumination – Nearest Available Site



(Source: National Renewable Energy Laboratory, Golden CO, 1995)

AVERAGE TRANSMITTED SOLAR RADIATION (Btu/sq.ft./day) FOR DOUBLE GLAZING, Percentage Uncertainty = 9		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year
HORIZ	Unshaded	380	580	810	1070	1300	1460	1450	1250	960	660	390	300	880
NORTH	Unshaded	130	180	240	300	360	410	390	320	250	190	140	110	250
	Shaded	110	160	210	260	320	360	340	280	220	160	110	96	220
EAST	Unshaded	290	400	510	640	740	800	800	710	580	440	270	230	540
	Shaded	250	350	430	530	610	660	660	590	500	380	240	200	450
SOUTH	Unshaded	780	830	750	650	570	530	550	650	760	830	660	650	680
	Shaded	750	760	580	400	350	360	360	380	530	720	630	630	540
WEST	Unshaded	290	390	510	620	730	810	820	740	610	440	280	230	540
	Shaded	250	340	430	520	610	670	680	620	520	380	240	200	460

AVERAGE INCIDENT ILLUMINANCE (klux-hr) FOR MOSTLY CLEAR AND MOSTLY CLOUDY CONDITIONS, Percentage Uncertainty = 9		March					June				
		9am	11am	1pm	3pm	5pm	9am	11am	1pm	3pm	5pm
HORIZ.	M.Clear	34	66	77	62	27	46	81	98	94	69
	M.Cloudy	21	42	50	39	17	30	57	71	71	51
NORTH	M.Clear	9	13	14	13	8	17	16	17	17	15
	M.Cloudy	9	15	17	14	7	14	17	19	19	16
EAST	M.Clear	71	57	14	13	8	77	73	34	17	15
	M.Cloudy	24	30	17	14	7	38	47	29	19	16
SOUTH	M.Clear	38	74	86	70	30	12	34	51	47	25
	M.Cloudy	16	35	43	33	13	11	27	39	37	21
WEST	M.Clear	9	13	19	64	65	12	16	17	49	78
	M.Cloudy	9	15	19	31	23	11	17	19	39	51
M.Clear	(% hrs)	28	27	26	26	27	36	35	32	29	32
		Sept					Dec				
		9am	11am	1pm	3pm	5pm	9am	11am	1pm	3pm	5pm
HORIZ.	M.Clear	25	62	81	75	47	10	35	41	26	1
	M.Cloudy	14	37	50	49	31	6	21	26	16	1
NORTH	M.Clear	8	13	15	15	11	4	9	10	7	1
	M.Cloudy	6	14	17	16	12	3	9	10	7	1
EAST	M.Clear	61	70	30	15	11	32	38	10	7	1
	M.Cloudy	19	32	23	16	12	8	16	10	7	1
SOUTH	M.Clear	19	57	78	72	42	29	77	87	62	3
	M.Cloudy	9	28	41	40	23	8	25	31	20	1
WEST	M.Clear	8	13	15	50	73	4	9	18	45	4
	M.Cloudy	6	14	17	31	35	3	9	13	16	1
M.Clear	(% hrs)	41	40	38	38	42	27	28	27	28	30

Wind Summary - December, January, and February



Labels of Percent Frequency on North Axis



Percent Calm = 4.19

Wind Summary - March, April, and May


Labels of Percent Frequency on North Axis



Percent Calm = 4.67

Wind Summary - June, July, and August


Labels of Percent Frequency on North Axis



Percent Calm = 7.67

Wind Summary - September, October, and November

Labels of Percent Frequency on North Axis



Percent Calm = 6.42